

## **Post Construction Stormwater Control Measure (SCM) Quick Reference**

### **1. Does your site have a stormwater permanent treatment practice (PTP) or stormwater control measure (SCM)?**

Examples include bioretention areas, detention ponds, underground water quality units, permeable pavements.



### **2. Is an annual report required for your site?**

Grading Permit Issue Year	Reporting Requirement	NPDES Inspection
Pre 2000	No Annual Report	Complaint-driven inspections and Random inspections based on 303(d) status of receiving stream*
2000 – Mid 2007	No Annual Report	Random Inspections based on 303(d) status of receiving stream
Mid 2007 - 2013	Owner submits Annual Report by July 1 of each year	Random Inspections based on 303(d) status of receiving stream
2014 – Onwards	- Owner submits Annual Report by July 1 of each year.  - All PTPs require inspection by a “qualified professional” every 5 years	Random Inspections based on 303(d) status of receiving stream  *303(d) status a state-determined classification

### **3. Are you in compliance? Do you know what your long term maintenance plan requires for inspections and maintenance?**

You may need to contract out inspection and maintenance of your SCM. This is particularly important if inspection and maintenance requires confined space entry (ie: underground water quality units).

***Failure to submit inspection and maintenance reports will result in enforcement.***

**If you don't know your grading permit number (first four digits is the year), or if you are unsure about SCMs on your property, call 880-2420 and speak with Rebecca Dohn.**